




Model J3

Wiring Diagram - AC or DC



Doc: J3/STD.WD/02
Feb 2010

AC (1ph) OR DC SUPPLY - WIRING FOR ON-OFF ACTUATORS



Note:
Volt free switches are set around 5° ahead of the final motor stop position. Do not use the signal from the volt free switches to cut the power to the motor otherwise the actuator will not reach the full open or full closed position.
The actuator is designed to have the power continuously energised.